

Temple Sowerby

Infiltration Reduction Plan

Last Updated: June 2026



Executive summary

Temple Sowerby in Cumbria is currently in the survey stage (see Figure 1) to address infiltration and reduce spills at the Temple Sowerby Wastewater Treatment Works Storm Overflow. An initial desktop assessment concluded that there was a possibility of infiltration. CCTV surveys have been recommended as a result and are due to be completed in Spring/Summer 2026.

If groundwater infiltration is found to be a likely leading cause of spills, interventions will be recommended, and this Infiltration Reduction Plan will be updated accordingly. If not, this plan will end at the survey stage and next steps will be processed through other relevant workstreams.




Figure 1: Iterative process to investigate, identify and address groundwater infiltration

Context

Sometimes, water can enter our wastewater pipes, for which they were not designed to receive. One source of these additional flows can be groundwater infiltration which can occur through pipe defects, leaky joints, or issues with manholes. Extra water in the network can cause the sewer capacity to be exceeded, leading to sewer flooding or contributing to overflow activations.

As part of our ongoing work to maintain an effective network and achieve Better Rivers for the North West, our Infiltration Reduction Plans demonstrate our efforts to date and next steps to address infiltration and inflows in the catchment. This plan covers the Temple Sowerby drainage area and its associated overflow, Temple Sowerby Wastewater Treatment Works Storm Overflow. In 2024, infiltration was identified as a potential leading cause of the overflow discharging. The purpose of this plan is to capture the process to investigate, identify, and address significant groundwater infiltration.




Figure 2: [United Utilities – Better Rivers – Storm Overflow Map \(October 2024\)](#). The green dot marks the Temple Sowerby Wastewater Treatment Works Storm Overflow

Temple Sowerby is located in the Eden Valley of Cumbria, on a broad and relatively flat valley floor. It lies just east of Penrith and outside the Lake District National Park. The landscape is primarily agricultural, with improved pastures enclosed by hedgerows and dry stone walls. Scattered woodlands and mature trees line the village green and surrounding fields.

The village lies close to the River Eden and its tributary, Crowdundle Beck, which influences local drainage and soil moisture. The flat valley floor supports seasonal wetlands and small tributary streams.

Investigation

An initial desktop study was undertaken using available data to understand the extent of infiltration in the sewer network of the drainage catchment. The following data (where available) was analysed to determine the scale and location of potential infiltration:

- Relevant flow and depth data
- Operational information
- MCERTS Data

- Hydraulic models of the catchment
- River Levels
- Groundwater (borehole) data
- Spill analysis
- Topographical and Sewer maps

The assessment indicated that infiltration may make up a proportion of flow. This could also have been affected by population growth in the area. The assessment highlighted potential sources of infiltration in the local area, and it was recommended that CCTV surveys be completed. CCTV surveys can also identify if there is land drainage connected into the sewer, which would be assessed for removal.

Survey

As recommended, CCTV surveys are currently underway and are due to be completed in Summer 2026.

Next steps

Temple Sowerby is currently in the survey stage of identifying and addressing infiltration. If groundwater infiltration is found to be a likely leading cause of spills, interventions will be recommended.